

Venue:

Fire Safety Curtain Inspection and Testing Log ANSI E1.22.2016 Requires the fire safety curtain emergency release be tested once every

30 performances but not less than every 3 months.

ANSI E1.22.2016 section 12.1 requires a logbook be kept for all maintenance and testing of the fire safety curtain.

NFPA 80 section 20.7.1.1 requires the fire safety curtain to be closed at all times except when the space is in use.

NFPA 80 section 20.9.1 requires the rigging be inspected annually by a qualified person

Date	Stage Left Pass Fail		Stage Right Pass Fail		Maint.	Notes	Initials

Date	Stage Left Pass Fail		Stage Right Pass Fail		Maint.	Notes	Initials